



Environmental Services Analysis Report - Final

| | | |
|------------------------------|--------------------|-------------------------------------|
| Invoice Number: 1068810 | | Collected Date: 30-Sep-2015 5:30 PM |
| Sample Location: Pump House | | Received: 01-Oct-2015 3:04 PM |
| Collected by: Dwayne Godlien | Permit: 2348 | Reported: 05-Oct-2015 4:28 PM |
| Station #: SK05JK0014 | MCLEAN DIST.SYSTEM | Water Source: Distributed |

| | |
|--|---|
| Submitted By: MCLEAN VILLAGE OF BOX 56 MCLEAN, SK S0G 3E0 | Invoice: MCLEAN VILLAGE OF BOX 56 MCLEAN, SK S0G 3E0 |
|--|---|

| Analysis | Result | Unit | Sask Guideline | Test Comment | Fee |
|---------------------------------------|--------|------------|----------------|--------------|-------|
| General Chemistry/Water Quality Panel | | | | | 94.50 |
| Conductivity | 640 | µS/cm | < 2300 | | |
| pH | 7.7 | pH Units | 6.5 - 9.0 | | |
| Total Alkalinity | 233 | mg/L CaCO3 | < 500 | | |
| Phenol Alkalinity | 0.00 | mg/L CaCO3 | No Guideline | | |
| Bicarbonate | 284 | mg/L | No Guideline | | |
| Carbonate | 0 | mg/L | No Guideline | | |
| Hydroxide | 0 | mg/L | No Guideline | | |
| Chloride Dissolved | 12.5 | mg/L | < 250 | | |
| Fluoride Dissolved | 0.11 | mg/L | < 1.5 | | |
| Nitrate Dissolved | 0.8 | mg/L | < 45 | | |
| Sulfate Dissolved | 100.5 | mg/L | < 500 | | |
| Total Hardness (Calculated) | 324 | mg/L CaCO3 | < 800 | | |
| Total Dissolved Solids | 526 | mg/L | < 1500 | | |
| Iron | <0.1 | mg/L | < 0.3 | | |
| Manganese | 0.19 | mg/L | < 0.05 | | |
| Calcium | 77 | mg/L | No Guideline | | |
| Magnesium | 32 | mg/L | < 200 | | |
| Potassium | 6 | mg/L | No Guideline | | |
| Sodium | 13 | mg/L | < 300 | | |



Environmental Services Analysis Report - Final

| | | | |
|-------------------------|---------------------|------------------------|---------------------|
| Invoice Number: | 1068810 | Collected Date: | 30-Sep-2015 5:30 PM |
| Sample Location: | Pump House | Received: | 01-Oct-2015 3:04 PM |
| Collected by: | Dwayne Godlien | Reported: | 05-Oct-2015 4:28 PM |
| Station #: | SK05JK0014 | Water Source: | Distributed |
| | Permit: 2348 | | |
| | MCLEAN DIST.SYSTEM | | |

Submitter Phone Number: 306-699-2314

Emailed results to: villageofmcleanoffice@sasktel.net

Comments:

Please include Invoice Number with payment and remit to:

**Minister of Finance
Saskatchewan Health
3475 Albert Street
Regina, Saskatchewan
S4S 6X6**

| | |
|--|-------|
| Total Fees (including GST) | 94.50 |
| Tax Summary | 4.50 |
| G.S.T. (reg # 107864258) | |
| Amount Received: (No Payment Received) | 0.00 |

Balance Due upon receipt of invoice.

| | |
|---------------------|----------------|
| Balance Owed | \$94.50 |
|---------------------|----------------|

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-787-6517
Billing Inquiries: Toll Free: 1-866-450-0000, Phone: (306) 787-7138, Fax: (306) 798-0046, Email: info@health.gov.sk.ca